Home Energy Rating Certificate

20 Harriet Road Gloucester, MA 01930



Confirmed HERS Index: 47

General Information

Conditioned Area 8429 sq. ft. House Type Single-family detached Conditioned Volume 110577 cubic ft. Foundation More than one type

Bedrooms

Mechanical Systems Features

Heating: Fuel-fired air distribution, Natural gas, 96.0 AFUE.

Cooling: Air conditioner, Electric, 15.0 SEER, w/DSH.

Cooling: Air conditioner, Electric, 17.0 SEER, w/DSH.

Duct Leakage to Outside RESNET/HERS default

Ventilation System Balanced: ERV, 120 cfm, 60.0 watts.

Programmable Thermostat Heat=Yes; Cool=Yes

Building Shell Features

Ceiling Flat R-10.0 Edge, R-10.0 Under NA Slab Sealed Attic R-38.0 **Exposed Floor** R-30.0 U-Value: 0.300, SHGC: 0.300 Vaulted Ceiling NA Window Type Above Grade Walls R-20.0 Infiltration Rate Htg: 2386 Clg: 2386 CFM50

Foundation Walls R-13.0 Blower door test Method

Lights and Appliance Features

Percent Interior Lighting 60.00 Range/Oven Fuel Natural gas Percent Garage Lighting 0.00 Clothes Dryer Fuel Natural gas Refrigerator (kWh/yr) 480.00 Clothes Dryer EF 2.67 Dishwasher Energy Factor 0.46 Ceiling Fan (cfm/Watt) 50.00

Registry ID 913170806 **Rating Number** 08291201

Certified Energy Rater Benjamin Marshall

Rating Date 8/29/2012 Rating Ordered For Henning

Estimated Annual Energy Cost			
Use	MMBtu	Cost	Percent
Heating	140.1	\$0	-1%
Cooling	6.0	\$0	-1%
Hot Water	16.4	\$0	-1%
Lights/Appliances	59.5	\$0	-1%
Photovoltaics	-0.0	\$-0	-1%
Service Charges		\$0	-1%
Total	221.9	\$0	100%
Criteria			

This home meets or exceeds the minimum criteria for the following:



TITLE Green Stamp Corp. Company 184 Riverview Ave Address Waltham, MA 02453 City, State, Zip (781)899 = 3618Phone # Fax #

The Home Energy Rating Standard Disclosure for this home is available from the rating provider.

REM/Rate - Residential Energy Analysis and Rating Software v14.4.1